

## TIER 3 PUBLIC NOTICE

### IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

#### Monitoring Requirements Not Met for Anway Manville Water Company AZ0410354

Our water system violated drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During February 2023 we did not take a compliant total coliform sample but a special sample was pulled after a repair to ensure the safety of water.

#### What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year; how often we are supposed to sample and how many samples we are supposed to take; how many samples we took; when samples should have been taken; and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When samples should have been taken	When samples were taken
Total Coliform	1 monthly	0	February 2023	March 2023

#### What is being done?

The subsequent total coliform samples have been pulled in accordance with ADEQ rules as of March 2023.

For more information, please contact Jason Long at 520-431-7723 or [jason@longwater.com](mailto:jason@longwater.com).

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Anway Manville Water Company  
State Water System ID#: AZ0410354  
Date distributed: 4/10/2023