

# CONSUMER CONFIDENCE REPORT

## Report Covers Calendar Year: January 1 – December 31, 2016

Este informe contiene información muy importante sobre el agua usted bebe. Tradúscalo ó hable con alguien que lo entienda bien.

### I. Public Water System (PWS) Information

PWS Name:	Baca Float Water Company				
PWS ID #	AZ04- 12-037				
Owner / Operator Name:	Baca Float Water Company				
Telephone #	520-398-3177	Fax #	520-398-9770	E-mail	bacawater@swbacanhelp.com
We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact <u>Richard Lockwood</u> at <u>520-398-3177</u> for additional opportunity and meetings dates and times.					

### II. Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.	
Our water source(s):	Groundwater

### III. Consecutive Connection Sources

A public water system that receives some or all of its finished water from one or more wholesale systems by means of a direct connection or through the distribution system of one or more consecutive systems. Systems that purchase water from another system report regulated contaminants detected from the source water supply in a separate table. <u>Baca Float Water Company does not receive water from any other water systems.</u>
---

### IV. Drinking Water Contaminants

<p><u>Microbial contaminants</u>, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.</p> <p><u>Inorganic contaminants</u>, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.</p> <p><u>Pesticides and herbicides</u> that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.</p> <p><u>Organic chemical contaminants</u>, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.</p> <p><u>Radioactive contaminants</u>, that can be naturally occurring or be the result of oil and gas production and mining activities.</p>
---

### V. Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by <i>Cryptosporidium</i> and microbiological contaminants call the EPA <i>Safe Drinking Water Hotline</i> at 1-800-426-4791.
---

### VI. Source Water Assessment

If the public water system received a Source Water Assessment (SWA), include a brief summary of the susceptibility as summarized in the SWA report. Further source water assessment documentation can be obtained by contacting ADEQ, 602-771-4641.
---

### VII. Definitions

<p><u>AL = Action Level</u> - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements.</p> <p><u>MCL = Maximum Contaminant Level</u> - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water.</p> <p><u>MCLG = Maximum Contaminant Level Goal</u> - The "Goal" is the level of a contaminant in drinking water below which there is no known or expected risk to health.</p> <p><u>MFL = Million fibers per liter.</u></p> <p><u>MRDL = Maximum Residual Disinfectant Level.</u></p> <p><u>MRDLG = Maximum Residual Disinfectant Level Goal.</u></p> <p><u>MREM = Millirems per year</u> – a measure of radiation absorbed by the body.</p> <p><u>NA = Not Applicable</u>, sampling was not completed by regulation or was not required.</p> <p><u>NTU = Nephelometric Turbidity Units</u>, a measure of water clarity.</p> <p><u>PCi/L = Picocuries per liter</u> - picocuries per liter is a measure of the radioactivity in water.</p> <p><u>PPM = Parts per million</u> or Milligrams per liter (mg/L).</p> <p><u>PPB = Parts per billion</u> or Micrograms per liter (µg/L).</p> <p><u>PPT = Parts per trillion</u> or Nanograms per liter.</p> <p><u>PPQ = Parts per quadrillion</u> or Picograms per liter.</p> <p><u>TT = Treatment Technique</u> - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td>ppm x 1000 = ppb</td> </tr> <tr> <td>ppb x 1000 = ppt</td> </tr> <tr> <td>ppt x 1000 = ppq</td> </tr> </table>	ppm x 1000 = ppb	ppb x 1000 = ppt	ppt x 1000 = ppq
ppm x 1000 = ppb				
ppb x 1000 = ppt				
ppt x 1000 = ppq				

### VIII. Health Effects Language

<u>Nitrate</u> in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.
--

If **arsenic** is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

## IX. Water Quality Data

<b>Microbiological</b>	<b>Violation Y or N</b>	<b>Number of Samples Present OR Highest Level Detected</b>	<b>Absent (A) or Present (P) OR Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Total Coliform Bacteria (System takes ≥ 40 monthly samples) 5% of monthly samples are positive; (System takes ≤ 40 monthly samples) 1 positive monthly sample Fecal coliform and E. Coli (TC Rule)	N	0	A	0	0	2016	Naturally Present in Environment
<b>Disinfectants</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA)</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Chlorine (ppm)	N	1.07	0.80 - 1.12	MRDL = 4	MRDLG = 4	2016	Water additive used to control microbes
<b>Disinfection By-Products</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Halooacetic Acids (ppb) (HAA5)	N	3.2	3.2	60	n/a	06/2016	Byproduct of drinking water disinfection
Total Trihalomethanes (ppb) (TTHM)	N	13.0	13.0	80	n/a	06/2016	Byproduct of drinking water disinfection
<b>Lead &amp; Copper</b>	<b>Violation Y or N</b>	<b>Percentile AND Number of Samples Over the AL</b>	<b>Range of All Samples (L-H)</b>	<b>AL</b>	<b>ALG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Copper (ppm)	N	0.059	.0056 – 0.059	AL = 1.3	ALG = 1.3	7/2016	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	N	0.0056	0.00 – 0.0056	AL = 15	0	7/2016	Corrosion of household plumbing systems; erosion of natural deposits
<b>Radionuclides</b>	<b>Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (L-H)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Alpha emitters (pCi/L) Includes Radon & Uranium	N	8.8	8.8	15	0	3/2015	Erosion of natural deposits

Inorganic Chemicals (IOC)	Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (L-H)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Antimony (ppb)	N	<1.0	<1.0	6	6	3/2015	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
Arsenic (ppb)	N	7.9	6.6 – 9.0	10	0	2016	deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium (ppm)	N	.014	.014	2	2	3/2015	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N	<1.0	<1.0	4	4	3/2015	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N	<0.5	<0.5	5	5	3/2015	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N	<1.0	<1.0	100	100	3/2015	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	N	<25.0	<25.0	200	200	3/2015	Discharge from steel/metal factories; steel/metal refineries and fertilizer factories
Fluoride (ppm)	N	1.0	1.0	4	4	3/2015	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Mercury (ppb)	N	<0.20	<0.20	2	2	3/2015	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland
Nitrate (ppm)	N	0.47	0.47	10	10	3/2016	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Selenium (ppb)	N	<5.0	<5.0	50	50	3/2015	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium (ppm)	N	43.0	43.0	N/A	N/A	3/2015	N/A
Thallium (ppb)	N	<1.0	<1.0	2	0.5	3/2015	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

#### X. Violations

Type / Description	Compliance Period	Corrective Actions taken by PWS

An explanation of the violation(s) in the above table, the steps taken to resolve the violation(s) and any required health effects information are required to be included with this report. (Attach copy of Public Notice if available.)