

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Desert Sky DWID PWS # AZ0415122
Has Levels of Arsenic Above Drinking Water Standards

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did (are doing) to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Testing results we received on 6/26/2025 show that our system exceeds the standard, or maximum contaminant level (MCL), for arsenic. The standard for arsenic is 10 parts per billion (ppb). The level of arsenic found at thirteen locations with the range of results of 23 ppb to 47 ppb

What should I do?

- There is nothing you need to do. **You do not need to boil your water or take other corrective actions.** However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water

What does this mean?

This is not an immediate risk. If it had, been you would have been notified immediately. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with circulatory system, and many have an increased risk of getting cancer.

What is being done?

The system is working closely with ADEQ and County to have the RO Filters replaced for the second time this year. We anticipate resolving the problem as soon as possible.

For more information, please contact Jason Long at 520-431-7723 or jason@longwatermgt.com

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Desert Sky DWID Public Water System ID#: AZ-04-15122 Date distributed: 7/31/2025

Any ADEQ translation or communication in a language other than English is unofficial and not binding on the State of Arizona.

Cualquier traducción o comunicado de ADEQ en un idioma diferente al inglés no es oficial y no sujetará al Estado de Arizona a ninguna obligación jurídica"