

Este informe contiene informactión muy importante sobre el aqua usted bebe. Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name			
AZ04-10317	Francesca Water Co Amber Ann			
Contact Name and Title		Phone Number	E-mail Address	
Jack Cullum Operations Manager		520-878-7438	jcullum@southwesternutility.com	

We want our valued customers to be informed about their water quality. If you would like to learn more, please contact Jack Cullum at 520-878-7438 or at jcullum@southwesternutility.com.

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

	Francesca Water Company is supplied by ground water from wells at a depth of 500 to 800 ft from the Santa Cruz
Our water source(s):	Basin.

Drinking Water Contaminants

Microbial Contaminants: Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Inorganic Contaminants: Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Pesticides and Herbicides: Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

Organic Chemical Contaminants: Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants: That can be naturally occurring or be the result of oil and gas production and mining activities.

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

Based on the information currently available on the hydrogeologic settings of and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the department has given a low risk designation for the degree to which this public water system drinking water source(s) are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection.

Further source water assessment documentation can be obtained by contacting ADEQ.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water

Maximum Contaminant Level Goal MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health

Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method

Millirems per year (MREM): A measure of radiation absorbed by the body

Not Applicable (NA): Sampling was not completed by regulation or was not required

Not Detected (ND or <): Not detectable at reporting limit

Nephelometric Turbidity Units (NTU): A measure of water clarity

Million fibers per liter (MFL)

Picocuries per liter (pCi/L): Measure of the radioactivity in water

ppm: Parts per million or Milligrams per liter (mg/L)

ppb: Parts per billion or Micrograms per liter (µg/L)

ppt : Parts per trillion or Nanograms per liter (ng/L)	ppm x 1000 = ppb
ppq : Parts per quadrillion or Picograms per liter (pg/L)	ppb x 1000 = ppt ppt x 1000 = ppq

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Francesca Water Company is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contaminati	
E. Coli	N	0	0	0	0		
Fecal Indicator(From GWR source)(coliphage, enterococci and/or E. coli)	N	0	0	0	0	Human and animal fecal waste	
¹ Total organic carbon (TOC) has no These byproducts include trihalomethane to adverse health effects, liver ² Turbidity is a measure of the cloudine indicator of the quality of water. High turbi with disinfection and provide a medium fo bacteria, viruses, and par	s (THM) and , or kidney pr ess of water a dity can hind r microbial gr	haloacetic acids (HA roblems, or nervous s and is an indication o er the effectiveness o rowth. Turbidity may	A). Drinking water system effects, an if the effectiveness of disinfectants. To indicate the prese	r containin d may lead s of our filt urbidity hat nce of dise	g these byp d to an incre ration syste s no health ease-causir	roducts in e eased risk o m. We mon effects. Hov ng organism	excess of the MCL may le f getting cancer. itor it because it is a gooc vever, turbidity can interfe s. These organisms inclu
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.36 ppm	0.21-0.87 ppm	4	0	12/2019	Water additive used to con microbes
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Total Trihalomethanes (TTHM) (ppb)	N	1.3 ppb	<.5-1.3 ppb	80	N/A	08/2019	Byproduct of drinking wate disinfection
Lead & Copper	MCL Violation Y or N	90 th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination
Copper (ppm)	N	0.015 ppm	0	1.3	1.3	09/2019	Corrosion of household plumbing systems; erosior natural deposits
Lead (ppb)	N	1.9 ppb	0	15	0	09/2019	Corrosion of household plumbing systems; erosior natural deposits
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Alpha Emitters (pCi/L) (This is Gross Alpha 4000)	N	5	5	15	0	10/2016	Erosion of natural deposit
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Arsenic ¹ (ppb)	N	6.3 ppb	6-6.3 ppb	10	0	06/2019	Erosion of natural deposit runoff from orchards, runo from glass and electronic production wastes
Barium (ppm)	N	.034 ppm	.031034 ppm	2	2	06/2019	Discharge of drilling waste discharge from metal refineries; Erosion of natu deposits
Chromium (ppb)	N	2.4 ppb	2.3-2.4 ppb	100	100	06/2019	Discharge from steel an pulp mills; Erosion of natu deposits
Fluoride (ppm)	N	0.54 ppm	0.52-0.54 ppm	4	4	06/2019	Erosion of natural deposi water additive which promotes strong teeth; discharge from fertilizer a aluminum factories
Nitrate ² (ppm)	N	1.7 ppm	1.6-1.7 ppm	10	10	06/2019	Runoff from fertilizer use leaching from septic tank sewage; erosion of natur deposits
Sodium (ppm)	N	33 ppm	33 ppm	N/A	N/A	06/2019	Erosion of natural deposi

Arsenic is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

² Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement).

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions			
Reporting	Did not submit Lead Consumer Notice to ADEQ on time Jan 01/2017-Decembe 31/2019	10 Days	Lead Consumer Notice was submitted to ADEQ on 10/25/2019 compliance achieved			
Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting						
this notice in a public place or distributing copies by hand or mail.						