

Consumer Confidence Report for Calendar Year 2023

Este informe contiene información muy importante sobre el agua usted bebe. Tradúscalo ó hable con alguien que lo entienda bien. Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name
AZ0420606	La Casita Water Company 3

Contact Name and Title	Phone Number	E-mail Address
Jason Long	520-431-7723	jason@longwatermgt.com

We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact Jason Long at 520-431-7723 for additional opportunity and meeting dates and times.

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s):

Our water system has 2 wells that draw water from the Upper Santa Cruz sub-basin of the Tucson Active Management Area basin.

Drinking Water Contaminants

Microbial Contaminants: Viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

Disinfectants and Disinfection By-products: Water additives used to control microbes, and the by-products of interactions between disinfectants and natural organic materials in water

Inorganic Contaminants: Salts, metals, and other inorganic contaminants that can occur naturally or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

Pesticides and Herbicides: Synthetic organic compounds that come from agriculture, urban storm water runoff, and a wide variety of residential uses

Organic Chemical Contaminants: Synthetic and volatile organic chemical by-products that come from industrial processes, petroleum production, gas stations, urban storm water runoff, and septic systems.

Radioactive Contaminants: Can be naturally occurring or be the result of oil and gas production and mining activities.

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

Based on the information currently available on the hydrogeologic settings of and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the department has given a low risk designation for the degree to which this public water system drinking water source(s) are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection.

Further source water assessment documentation can be obtained by contacting ADEQ.

Definitions

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

Level 2 Assessment: A very detailed study of the water system to identify potential problems contributing to an *E. coli* MCL violation, and/or why total coliform bacteria was present

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water

Maximum Contaminant Level Goal MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health

Maximum Residual Disinfectant Level (MRDL): The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

Maximum Residual Disinfectant Level Goal (MRDLG): The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method

Millirems per year (MREM): A measure of radiation absorbed by the body

Not Applicable (NA): Sampling was not completed by regulation or was not required

Not Detected (ND or <): Not detected by the sampling laboratory above a minimum level of detection

Nephelometric Turbidity Units (NTU): Measure of water clarity for drinking water systems using surface water as source water

Million fibers per liter (MFL): Measure of asbestos contamination

Picocuries per liter (pCi/L): Measure of the radioactivity in water

Unit Conversions:

ppm: Parts per million or Milligrams per liter (mg/L)
 $\text{ppm} \times 1000 = \text{ppb}$

ppb: Parts per billion or Micrograms per liter ($\mu\text{g/L}$)
 $\text{ppb} \times 1000 = \text{ppt}$

ppt: Parts per trillion or Nanograms per liter (ng/L)
 $\text{ppt} \times 1000 = \text{ppq}$

ppq: Parts per quadrillion or Picograms per liter (pg/L)

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. La Casita Water Company 3 is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Water Quality Data – Regulated Contaminants

As authorized and approved by EPA, the state has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. Some of our data, though representative, is more than one year old.

Disinfectants	MCL Violation Y or N	Average	Range	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Chlorine/Chloramine (ppm)	N	0.39	0.12 to 1.12	4	4	2023	Water additive used to control microbes
Radionuclides	MCL Violation Y or N	Average or Highest Level Detected	Range	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Alpha Emitters including uranium (pCi/L)	N	9.2	7.57 to 9.2	15	0	2020 - 2023	
Inorganic Chemicals (IOC)	MCL Violation Y or N	Average or Highest Level Detected	Range	MCL	MCLG	Sample Month & Year	Likely Source of Contamination
Arsenic ¹ (ppb)	N	2.6	2.3 to 2.6	10	0	2020 - 2023	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Barium (ppm)	N	0.098	0.097 to 0.098	2	2	2020 - 2023	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Chromium (ppb)	N	1.6	0 to 1.6	100	100	2020 - 2023	Discharge from steel and pulp mills; Erosion of natural deposits
Fluoride (ppm)	N	0.3	0.28 to 0.3	4	4	2020 - 2023	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Nitrate ² (ppm)	N	3.5	3.5 to 3.5	10	10	5 / 2023	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Sodium (ppm)	N	38	34 to 38	N/A	N/A	2021 - 2023	Erosion of natural deposits

Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

Violation Type	Explanation, Health Effects	Time Period	Corrective Actions
Missed Monitoring	Disinfection Byproducts (HAA5, TTHM)	2023	Will return to compliance with sampling in 2024

Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.