

Consumer Confidence Report for Calendar Year 2021

Este informe contiene informactión muy importante sobre el aqua usted bebe. Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name					
AZ0412005	Sonoita Valley Water Company - South					
Contact Name and Title		Phone Number	E-mail Address			
Allison Hahn, Compliance Manager		602-795-8291	Compliance@southwesternutility.com			
		002-795-0291	Compliance @ southwesternutility.			

We want our valued customers to be informed about their water quality. If you would like to learn more, please contact Jason Long at 520-431-7723.

Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water source(s): Two active wells that withdraw water from within the Cienega Creek Basin.

Drinking Water Contaminants

Microbial Contaminants: Such as viruses and bacteria Organic Chemical Contaminants: Such as synthetic and volatile organic chemicals, which are by-products of industrial that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems. Inorganic Contaminants: Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil Radioactive Contaminants: That can be naturally occurring and gas production, mining, or farming or be the result of oil and gas production and mining activities. **Pesticides and Herbicides**: Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

Source Water Assessment

Based on the information currently available on the hydrogeologic settings and the adjacent land uses that are in the specified proximity of the drinking water source(s) of this public water system, the Arizona Department of Environmental Quality (ADEQ) has given a high risk designation for the degree to which this public water system drinking water source(s) are protected. A designation of high risk indicates there may be additional source water protection measures which can be implemented on the local level. This does not imply that the source water is contaminated nor does it mean that contamination is imminent. Rather, it simply states that land use activities or hydrogeologic conditions exist that make the source water susceptible to possible future contamination. Further source water assessment documentation can be obtained by contacting ADEQ.

Definitions

Treatment Technique (TT) : A required process intended to reduce the level of a contaminant in drinking water	Minimum Reporting Limit (MRL): The smallest measured concentration of a substance that can be reliably measured by a given analytical method				
Level 1 Assessment : A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present	Millirems per year (MREM): A measure of radiation absorbed by the body				
Level 2 Assessment : A very detailed study of the water system to identify potential problems and determine (if	Not Applicable (NA): Sampling was not completed by regulation or was not required				
possible) why an <i>E. coli</i> MCL violation has occurred and/or why total coliform bacteria was present	Not Detected (ND or <): Not detectable at reporting limit				
Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements	Nephelometric Turbidity Units (NTU): A measure of water clarity				
Maximum Contaminant Level (MCL): The highest level of a	Million fibers per liter (MFL)				
contaminant that is allowed in drinking water	Picocuries per liter (pCi/L): Measure of the radioactivity				
Maximum Contaminant Level Goal MCLG): The level of a	in water				
contaminant in drinking water below which there is no known or expected risk to health	ppm : Parts per million or Milligrams per liter (mg/L)				
	ppb : Parts per billion or Micrograms per liter (µg/L)				
Maximum Residual Disinfectant Level (MRDL) : The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap	ppt : Parts per trillion orNanograms per liter (ng/L)ppm x 1000 = ppb				
Maximum Residual Disinfectant Level Goal (MRDLG): The	ppq : Parts per quadrillion or ppb x $1000 = ppt$				
level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur	Picograms per liter (pg/L) ppt x 1000 = ppq				

Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Sonoita Valley Water Company - South is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at www.epa.gov/safewater/lead.

Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

monitoring for Combined								
m in 2 nd and 3 rd quarter	2021	Submitted results in 4 st quarter of 2021						
nonitoring for Gross Alpha ides in 2 nd and 3 rd quarter	2021	Submitted results in 4 st quarter of 2021						
Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail								
)	ides in 2 nd and 3 rd quarter other people who drink th in apartments, nursing ho	ides in 2 nd and 3 rd quarter 2021 other people who drink this water, especially those						

Water Quality Data – Regulated Contaminants

Water Quality Data – Regulated Contaminants										
Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination				
E. Coli	N	0	N/A	0	0	Human and animal fecal waste				
Fecal Indicator (coliphage, enterococci and/or E. coli)	N	0	N/A	0	0	Human and animal fecal waste				
Disinfectants	MCL Violation Y or N	Running Annual Average (RAA)	Range of All Samples (Low-High)	MRDL	MRDL G	Sample Month & Year	Likely Source of Contamination			
Chlorine/Chloramine (ppm)	N	0.70	0.5 – 1.01	4	0	2021	Water additive used to control microbes			
Disinfection By-Products	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination			
Haloacetic Acids (HAA5) (ppb)	N	ND	ND	60	N/A	07/2021	Byproduct of drinking water disinfection			
Total Trihalomethanes (TTHM) (ppb)	N	0.60	0.60	80	N/A	07/2021	Byproduct of drinking water disinfection			
Lead & Copper	MCL Violation Y or N	90 th Percentile	Number of Samples Exceeds AL	AL	ALG	Sample Month & Year	Likely Source of Contamination			
Copper (ppm)	N	0.081	0	1.3	1.3	09/2021	Corrosion of household plumbing systems; erosion of natural deposits			
Lead (ppb)	N	ND	0	15	0	09/2021	Corrosion of household plumbing systems; erosion of natural deposits			
Radionuclides	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination			
Alpha Emitters (pCi/L)	N	11.1	ND – 21.0	15	0	1/2021 11/2021	Erosion of natural deposits			
Combined Uranium (ppb)	N	4.15	ND – 8.3	30	0	1/2021 11/2021	Erosion of natural deposits			
Inorganic Chemicals (IOC)	MCL Violation Y or N	Running Annual Average (RAA) <u>OR</u> Highest Level Detected	Range of All Samples (Low-High)	MCL	MCLG	Sample Month & Year	Likely Source of Contamination			
Arsenic ¹ (ppb)	N	5.4	3.8 - 5.4	10	0	05/2021	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes			
Barium (ppm)	N	0.37	0.013 - 0.37	2	2	05/2021	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits			
Fluoride (ppm)	N	0.17	0.15 - 0.17	4	4	05/2021	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories			
Nitrate ² (ppm)	N	1.0	1.0	10	10	05/2021	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits			
Sodium (ppm)	N	30	9 - 30	N/A	N/A	05/2021	Erosion of natural deposits			

¹ Arsenic is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

² Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

All contaminants listed below were tested for and were NOT found in our water. These contaminants are considered Non-Detect or not present:

Inorganic Contaminants (Last tested 5/2021): Antimony, Beryllium, Cadmium, Chromium, Cyanide, Mercury, Nickel, Nitrite, Selenium, Thallium

Synthetic Organic Compounds (Last tested 5/2021): 2,4-D, 2,4,5-TP (a.k.a. Silvex), Acrylamide, Alachlor, Atrazine, Benzo (a) pyrene (PAH), Carbofuran, Chlordane, Dalapon, Di (2-ethylhexyl) adipate, Di (2-ethylhexyl) phthalate, Dibromochloropropane, Dinoseb, Diquat, Dioxin [a.k.a. 2,3,7,8-TCDD], Endothall, Endrin, Epichlorohydrin, Ethylene dibromide, Glyphosate, Heptachlor, Heptachlor epoxide, Hexachlorobenzene, Hexachlorocyclo pentadiene, Lindane, Methoxychlor, Oxamyl (a.k.a. Vydate), PCBs [Polychlorinated biphenyls], Pentachlorophenol, Picloram, Simazine, Toxaphene

Volatile Organic Compounds (Last tested 5/2021): Benzene, Carbon tetrachloride, Chlorobenzene, o-Dichlorobenzene, p-Dichlorobenzene, 1,2-Dichloroethane, 1,1-Dichloroethylene, cis-1,2-Dichloroethylene, trans-1,2-Dichloroethylene, Dichloromethane, 1,2-Dichloropropane, Ethylbenzene, Styrene, Tetrachloroethylene, 1,2,4-Trichlorobenzene, 1,1,1-Trichloroethane, 1,1,2-Trichloroethane, Trichloroethylene, Toluene, Vinyl Chloride, Xylenes