



2018 ANNUAL WATER QUALITY REPORT

Spanish Trail Water Company

PWS# 10-127

June 2019

Esta es informacion importante. Si no la pueden leer, necesitan que alguien se la traduzca.

We are pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water.

Water System #10-127, known as **Spanish Trail Water Company**, currently serves a **population of approximately 1,180 people** throughout the year, and has 420 service connections. The water source comes from **three** wells.

If you have any questions about this report or concerning your water utility, please contact **Chris Hill** at **(520)904-0741**. **Some people may be more vulnerable to contaminants in drinking water than the public in general.**

All drinking water, including bottled water, may reasonably be expected to contain at

least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk of infections. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by cryptosporidium and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides** that may come from a variety of sources, such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and also may come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The U.S. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.

The table of detected contaminants contains many terms and abbreviations that may be unfamiliar. To help you better understand these terms we've provided the following definitions:

- *Action Level (AL): The concentration of a contaminant, if exceeded, triggers treatment or other requirements a water system must follow.*
- *Maximum Contaminant Level (MCL): The "maximum allowed" is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.*
- *Maximum Contaminant Level Goal (MCLG): The "goal" is the level of a contaminant in drinking water, below which there is no known or expected risk to*

health. MCLGs allow for a margin of safety.

- **Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **Nephelometric Turbidity Unit (NTU):** Nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of five NTU is just noticeable to the average person.
- **Not Detected (ND) or Below Detection Level (BDL):** Laboratory analysis indicates that the contaminant is not present. (“<” Symbol for less than, the same as ND or BDL)
- **Not Tested (NT):** Contaminant was not tested.
- **Parts per billion (ppb) or Micrograms per liter (µg/l):** One part per billion corresponds to one minute in 2,000 years, or one penny in \$10,000,000.
- **Parts per million (ppm) or Milligrams per liter (mg/l):** One part per million corresponds to one minute in two years or one penny in \$10,000.
- **Parts per quadrillion (ppq) or Picograms per liter (pg/l):** One part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.
- **Parts per trillion (ppt) or Nanograms per liter (ng/l):** One part per trillion corresponds to one minute in 2,000,000 years, or one penny in \$10,000,000,000.
- **PicoCuries per Liter (pCi/l):** A measure of radioactivity in water.
- **Total Organic Carbon (TOC):** A measure of the total amount of carbon in water, present as organic molecules.
- **Treatment Technique (TT):** A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Additional Information

Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods-of-time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider.

If **arsenic** is less than 10 ppb, your drinking water meets EPA’s standards. EPA’s standard balances the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Infants and young children are typically more vulnerable to **lead** in drinking water than

the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home's plumbing. If you are concerned about elevated lead levels in your home's water, you may wish to have your water tested. Flush your tap for 30 seconds to 2 minutes before using tap water. Additional information is available from the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.



Table of Contaminants

The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. **Some of our data, though representative, may be more than one year old.**

This table shows the results of our monitoring for the period of January 1 to December 31, 2017 unless otherwise noted.

Microbiological Contaminants							
Contaminant	MCL	MCLG	Unit	System Result	Violation Yes or No	Sample Date(s)	Likely Cont.
Total Coliform Bacteria for Systems that collects <40 samples per month	<1 positive monthly sample	0	Absent or Present	Absent	No	Jan. – Dec. 2018	Natural the en

Disinfectants and Disinfection Byproducts

Contaminant	MCL/ MRDL	MCLG/ MRDLG	Units	Average Level Detected & Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Chlorine Residual	4	0	ppm	0.17 0.0 to 0.42	No	Running Annual Average – 2018	Water additive used to control microb

Inorganic Contaminants

Contaminant	MCL	MCLG	Units	Level Detected	Violation Yes or No	Sample Dates	Likely Source of Contamination
Nitrate (as Nitrogen)	10	10	ppm	2.03 (1.3 to 3.3)	No	12/03/18	Runoff from fertilizer use; leaching fr tanks, sewage; erosion of natural depo

Lead and Copper

Contaminant	AL	ALG	Units	Maximum Level Detected and Range of Detections	90 th Percentile Value and Number of Samples Over the AL	Violation – Yes/No	Sample Dates	Likely Source of Contamina
Copper	1300	0	ppb	600 <20 to 600	710 None over the AL	No	Sept 2018	Corrosion of household plumbing erosion of natural deposits; leaching preservatives
Lead	15	0	ppb	7.8 <5.0 to 25.8	8.7 None over the AL	No	Sept 2018	Corrosion of household plumbing erosion of natural deposit

Synthetic Organic Contaminants, including Pesticides and Herbicides

Contaminant	MCL	MCLG	Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
2,4-D	70	70	ppb	<0.1	No	10/19/2016	Runoff from herbicide used on row crop
2,4,5-TP (Silvex)	50	50	ppb	<0.2	No	10/19/2016	Residue of banned herbicide
Alachlor	2	0	ppb	<0.1	No	10/19/2016	Runoff from herbicide used on row crop

Contaminant	MCL	MCLG	Units	Level Detected /Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Atrazine	3	3	ppb	<0.1	No	10/19/2016	Runoff from herbicide used on row crop

Benzo (a) pyrene (PAH)	200	0	ppt	<20	No	10/19/2016	Leaching from linings of water storage tanks and distribution lines
Carbofuran	40	40	ppb	<0.9	No	10/19/2016	Leaching of soil fumigant used on rice and other crops
Chlordane	2	0	ppb	<0.1	No	10/19/2016	Residue of banned termiticide
Dalapon	200	200	ppb	<1.0	No	10/19/2016	Runoff from herbicide used on rights of way
Di (2-ethylhexyl) adipate	400	400	ppb	<0.6	No	10/19/2016	Discharge from chemical factories
Di (2-ethylhexyl) phthalate	6	0	ppb	<0.6	No	10/19/2016	Discharge from rubber and chemical factories
Dibromochloropropane (DBCP)	0.2	0	ppb	<0.01	No	10/19/2016	Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and other crops
Dinoseb	7	7	ppb	<0.2	No	10/19/2016	Runoff from herbicide used on soybeans and other vegetables
Diquat	20	20	ppb	<0.4	No	10/19/2016	Runoff from herbicide use
Dioxin [2,3,7,8-TCDD]	30	0	ppq	<0.255	No	10/19/2016	Emissions from waste incineration and other combustion; discharge from chemical factories
Endothall	100	100	ppb	<9.0	No	10/19/2016	Runoff from herbicide use
Endrin	2	2	ppb	<0.01	No	10/19/2016	Residue of banned insecticide
Ethylene dibromide (EDB)	0.05	0	ppb	<0.01	No	10/19/2016	Discharge from petroleum refineries
Glyphosate	700	700	ppb	<6.0	No	10/19/2016	Runoff from herbicide use
Heptachlor	0.4	0	ppb	<0.01	No	10/19/2016	Residue of banned termiticide
Heptachlor epoxide	0.2	0	ppb	<0.01	No	10/19/2016	Breakdown of heptachlor
Hexachlorobenzene	1	0	ppb	<0.1	No	10/19/2016	Discharge from metal refineries and agricultural chemical factories
Hexachlorocyclopentadiene	50	50	ppb	<0.1	No	10/19/2016	Discharge from chemical factories
Lindane	0.02	200	ppb	<0.01	No	10/19/2016	Runoff/leaching from insecticide used on lumber, gardens
Methoxychlor	40	40	ppb	<0.05	No	12/16/2016	Runoff/leaching from insecticide used on vegetables, alfalfa, livestock
Oxamyl [Vydate]	200	200	ppb	<2.0	No	10/19/2016	Runoff/leaching from insecticide used on potatoes and tomatoes
PCBs [Polychlorinated biphenyls]	500	0	ppt	<100	No	10/19/2016	Runoff from landfills; discharge of waste from chemical factories
Pentachlorophenol	1	0	ppb	<0.4	No	10/19/2016	Discharge from wood preserving factories
Picloram	500	500	ppb	<0.1	No	10/19/2016	Herbicide runoff
Simazine	4	4	ppb	<0.05	No	10/19/2016	Herbicide runoff
Toxaphene	3	0	ppb	<0.5	No	10/19/2016	Runoff/leaching from insecticide used on cattle

Volatile Organic Contaminants

Contaminant	MCL	MCLG	Units	Level Detected/Range	Violation Yes or No	Sample Date	Likely Source of Contamination
Benzene	5	0	ppb	<0.5	No	10/19/2016	Discharge from factories; leaching from storage tanks and landfills
Carbon tetrachloride	5	0	ppb	<0.5	No	10/19/2016	Discharge from chemical plants and other industrial activities
Chlorobenzene	100	100	ppb	<0.5	No	10/19/2016	Discharge from chemical and agricultural chemical factories
o-Dichlorobenzene	600	600	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories
p-Dichlorobenzene	75	75	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories
1,2-Dichloroethane	5	0	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories

1,1-Dichloroethylene	7	7	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories
cis-1,2-Dichloroethylene	70	70	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories

Contaminant	MCL	MCLG	Units	Level Detected/Range	Violation Yes or No	Sample Date	Likely Source of Contamination
trans-1,2-Dichloroethylene	100	100	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories
Dichloromethane	5	0	ppb	<0.5	No	10/19/2016	Discharge from pharmaceutical and chemical factories
1,2-Dichloropropane	5	0	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories
Ethylbenzene	700	700	ppb	<0.5	No	10/19/2016	Discharge from petroleum refineries
Styrene	100	100	ppb	<0.5	No	10/19/2016	Discharge from rubber and plastic factories from landfills
Tetrachloroethylene	5	0	ppb	<0.5	No	10/19/2016	Discharge from factories and dry cleaners
1,2,4-Trichlorobenzene	70	70	ppb	<0.5	No	10/19/2016	Discharge from textile-finishing factories
1,1,1-Trichloroethane	200	200	ppb	<0.5	No	10/19/2016	Discharge from metal degreasing sites and factories
1,1,2-Trichloroethane	5	3	ppb	<0.5	No	10/19/2016	Discharge from industrial chemical factories
Trichloroethylene	5	0	ppb	<0.5	No	10/19/2016	Discharge from metal degreasing sites and factories
Toluene	1	1	ppb	<0.5	No	10/19/2016	Discharge from petroleum factories
Vinyl Chloride	2	0	ppb	<0.5	No	10/19/2016	Leaching from PVC piping; discharge from factories
Total Xylenes	10	10	ppb	<0.5	No	10/19/2016	Discharge from petroleum factories; discharge from chemical factories

Unregulated Contaminants

Unregulated contaminants are those for which the System is not required to monitor for, or that EPA has not established drinking water standards. There were no unregulated contaminants monitored in 2018.

There were no monitoring or reporting violations that occurred in 2018 at Spanish Trail Water Company.

This year's CCR serves as notice that Public Notification pursuant to R18-4-105.F

as been served to all customers of this public water system and to the State of Arizona, Department of Environmental Quality, June 2019.